## **SIEMENS**

Data sheet 6EP1332-1SH71



SIMATIC PM1207/1AC/24VDC/2.5A

SIMATIC S7-1200 Power Module PM1207 Stabilized power supply input: 120/230 V AC, output: DC 24 V/2,5 A

nput		
type of the power supply network	1-phase AC	
supply voltage at AC	Automatic range selection	
supply voltage	120 V/230 V	
input voltage 1 at AC	85 132 V	
input voltage 2 at AC	176 264 V	
wide range input	No	
overvoltage overload capability	2.3 × Vin rated, 1.3 ms	
buffering time for rated value of the output current in the event of power failure minimum	20 ms	
operating condition of the mains buffering	at Vin = 93/187 V	
line frequency	50/60 Hz	
line frequency	47 63 Hz	
input current		
<ul> <li>at rated input voltage 120 V</li> </ul>	1.2 A	
<ul> <li>at rated input voltage 230 V</li> </ul>	0.67 A	
current limitation of inrush current at 25 °C maximum	13 A	
duration of inrush current limiting at 25 °C		
• maximum	3 ms	
I2t value maximum	0.5 A²·s	
fuse protection type	T 3,15 A/250 V (not accessible)	
fuse protection type in the feeder	Recommended miniature circuit breaker: 16 A characteristic B or 10 A characteristic C	
utput		
voltage curve at output	Controlled, isolated DC voltage	
output voltage at DC rated value	24 V	
output voltage		
at output 1 at DC rated value	24 V	
output voltage adjustable	No; -	
relative control precision of the output voltage		
relative control precision of the output voltage  • on slow fluctuation of input voltage	0.1 %	
	0.1 % 0.2 %	
on slow fluctuation of input voltage		
on slow fluctuation of input voltage     on slow fluctuation of ohm loading		
on slow fluctuation of input voltage     on slow fluctuation of ohm loading residual ripple	0.2 %	
on slow fluctuation of input voltage     on slow fluctuation of ohm loading  residual ripple     maximum	0.2 %	
on slow fluctuation of input voltage     on slow fluctuation of ohm loading  residual ripple     maximum  voltage peak	0.2 % 150 mV	
on slow fluctuation of input voltage     on slow fluctuation of ohm loading residual ripple     maximum voltage peak     maximum	0.2 % 150 mV 240 mV	

• typical	10 ms	
typical     output current	10 1115	
rated value	2.5 A	
• rated range	0 2.5 A	
•		
supplied active power typical	60 W	
short-term overload current		
on short-circuiting during the start-up typical	6 A	
at short-circuit during operation typical	6 A	
duration of overloading capability for excess current		
on short-circuiting during the start-up	100 ms	
at short-circuit during operation	100 ms	
bridging of equipment	Yes	
number of parallel-switched equipment resources for increasing the power	2	
efficiency		
efficiency in percent	83 %	
power loss [W]	00 N	
at rated output voltage for rated value of the output current typical	12 W	
closed-loop control		
relative control precision of the output voltage with rapid	0.3 %	
fluctuation of the input voltage by +/- 15% typical		
relative control precision of the output voltage load step of resistive load 50/100/50 % typical	3 %	
setting time		
<ul><li>load step 50 to 100% typical</li></ul>	5 ms	
● load step 100 to 50% typical	5 ms	
setting time		
maximum	5 ms	
protection and monitoring		
design of the overvoltage protection	< 33 V	
property of the output short-circuit proof	Yes	
design of short-circuit protection	Constant current characteristic	
• typical	2.65 A	
enduring short circuit current RMS value		
• typical	2.7 A	
safety		
galvanic isolation between input and output	Yes	
galvanic isolation	Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178	
operating resource protection class	Class I	
leakage current		
maximum	3.5 mA	
protection class IP	IP20	
standard		
• for emitted interference	EN 55022 Class B	
<ul> <li>for mains harmonics limitation</li> </ul>	not applicable	
for interference immunity	EN 61000-6-2	
standards, specifications, approvals		
certificate of suitability		
• CE marking	Yes	
UL approval	Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus- Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273	
CSA approval	Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus-Recognized (UL 60950-1, CSA C22.2 No. 60950-1) File E151273	
EAC approval	Yes	
NEC Class 2	Yes; according to UL1310, File E151273	
type of certification		
CB-certificate	Yes	
MTBF at 40 °C	1 492 537 h	
standards, specifications, approvals hazardous environments		
certificate of suitability		
• IECEx	Yes; IECEx Ex nA nC IIC T4 Gc	

ATEN	V ATEV (EV) II 00 E A G	NUO T4 O		
ATEX      Ul horizon approval	Yes; ATEX (EX) II 3G Ex nA nC	, IIC 14 GC		
<ul><li>ULhazloc approval</li><li>cCSAus, Class 1, Division 2</li></ul>	Yes			
FM registration	No Yes; Class I, Div. 2, Group ABCD, T4			
standards, specifications, approvals marine classification	res, class i, biv. 2, Gloup Abc	,D, 14		
shipbuilding approval	Yes			
Marine classification association	1 63			
American Bureau of Shipping Europe Ltd. (ABS)	Yes			
French marine classification society (BV)	Yes			
Det Norske Veritas (DNV)	Yes			
Lloyds Register of Shipping (LRS)	Yes			
Nippon Kaiji Kyokai (NK)	Yes			
ambient conditions				
ambient temperature				
during operation	0 60 °C; with natural convect	ion		
during transport	-40 +85 °C			
during storage	-40 +85 °C			
environmental category according to IEC 60721	Climate class 3K3, 5 95% no	condensation		
connection method				
type of electrical connection	screw terminal			
• at input	L, N, PE: 1 screw terminal each	for 0.5 2.5 mm <sup>2</sup>		
at output	L+, M: 2 screw terminals each for 0.5 2.5 mm <sup>2</sup>			
for auxiliary contacts	-			
mechanical data				
width × height × depth of the enclosure	70 × 75			
installation width × mounting height	70 mm			
required spacing				
• top	20 mm			
• bottom	20 mm			
• left	0 mm			
• right	0 mm			
fastening method	Snaps onto DIN rail EN 60715 35x7.5/15, wall mounting			
<ul> <li>standard rail mounting</li> </ul>	Yes			
<ul> <li>S7 rail mounting</li> </ul>	No			
wall mounting	Yes			
housing can be lined up	Yes			
net weight	0.3 kg			
additional information				
other information	Specifications at rated input vol otherwise specified)	tage and ambient temper	rature +25 °C (unless	
security information				
Security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)			
Classifications				
		Version	Classification	
	eClass	14	27-04-07-01	
	eClass	12	27-04-07-01	

eClass	9.1	27-04-07-01
eClass	9	27-04-07-01
eClass	8	27-04-90-02
eClass	7.1	27-04-90-02
eClass	6	27-04-90-02
ETIM	9	EC002540
ETIM	8	EC002540
ETIM	7	EC002540
IDEA	4	4130
UNSPSC	15	39-12-10-04

Approvals Certificates

**General Product Approval** 





Confirmation







Marine / Shipping EMV **Test Certificates** 



<u>KC</u>

Special Test Certific-<u>ate</u>

Type Test Certificates/Test Report





other Railway Environment Confirmation Special Test Certific-Environmental Con-<u>ate</u> firmations

last modified:

5/7/2024

